

DERWENT LONDON



Network Building

Fire Safety Management Plan & Fire Evacuation Procedures

Contents

- 1.0 Introduction
- 2.0 Means of Escape in Case of Fire
- 3.0 Means for Giving Warning in Case of Fire
- 4.0 Means for Fighting Fire
- 5.0 Discovering a Fire
- 6.0 Evacuation Procedure
- 7.0 Assistance to Emergency Services
- 8.0 Procedures for Persons Working Out of Normal Hours
- 9.0 Fire watch contingency plan

1.0 Introduction

When a fire breaks out in a building in, which people are present, the primary need is for those people to be able to escape safely and quickly. Special experience and knowledge are needed to plan in advance what the escape routes should be and how they should be protected and equipped so that they will remain effective in an emergency for as long as necessary.

Being prepared will greatly reduce the likelihood of the fire emergency procedures not being effectively carried out. It is vital at all times that you are prepared.

This building is provided with reception and security staff, a comprehensive fire alarm system, trained fire wardens, competent management and a Health & Safety Management System with a Fire Risk Assessment carried out each year it is therefore considered that this building is classed as a 'Managed Building'.

All Persons at the **Network Building** should be aware of the following, with responsible persons needing to be prepared in their additional areas as indicated below.

The requirement of The Regulatory Reform Order 2005 (Fire Safety) (RRO), which came into force 1st October 2006.

The order has introduced radical and wide-ranging reforms to fire safety legislation in England and Wales. The legislative regime applies to most non-domestic properties and requires "A Responsible Person" – defined in the case of a workplace as the Employer to the extent that the workplace is under his control and is to carry out a "Fire Risk Assessment" to ensure that the more detailed fire safety requirements of the RRO are being met. As well as an "Alterations Notice" a Fire Inspector (as defined in the RRO),

A FIRE INSPECTOR CAN ISSUE ENFORCEMENT AND PROHIBITION NOTICES AS THEY DEEM NECESSARY.

1.1 All Persons

General Fire Prevention

Know what action is to be taken on discovering a fire.

Know where to find firefighting equipment and fire alarm call points.

Know how to use an extinguisher.

Know the layout of your floor.

Know your escape routes.

Know your assembly point.

Know what action is to be taken on hearing the fire alarm.

Know your floor wardens and their deputies.

Look after, and escort your visitors and contractors to the assembly area.

Fire Evacuation Procedures

Network Building, 97 Tottenham Court Road, London, W1

Under the Fire Safety Regulatory Reform Order 2005 (Fire Safety) tenants are responsible for ensuring that the correct frequency of fire training for their employees is carried out and are recorded for audit purposes.

Each employee is to receive fire training with practical exercises where possible.

- 1. On induction training.**
- 2. On an annual basis thereafter.**
- 3. The Landlord will conduct a Fire Evacuation Drill every six (6) months.**

The Landlord undertakes an annual Fire Risk Assessment for the building which includes all areas where the Landlord has responsibility (Plant Rooms, Common Area etc); this is to assess the impact on the remainder of premises.

Tenants are responsible for their own demise and are required to have competent person carry out a Fire Risk Assessment of their areas of responsibility. Any "Significant Findings" arising out of the Fire Risk Assessment **must be** communicated to the Landlord.

On majority request the Landlord will provide Fire Warden Training once a year.

Landlord is responsible for the servicing of the;

- Landlord area Fire Extinguishers
- Common area Emergency Lighting
- Smoke Ventilation System
- Hose reels & Sprinkler systems in car park areas
- All of the Fire Alarm System

2.0 Means of Escape in Case of Fire

2.1 INTRODUCTION

Means of escape in case of fire can be defined as “structural route” forming an integral part of the building whereby persons can escape from fire by their own unaided efforts to a place of “Ultimate” Safety or “Comparative” Safety’.

For example, if a person leaves the building from any level and exits direct to open air, then they are in a place of “Ultimate” safety. However, if entering a staircase from an upper floor of offices and the staircase is enclosed by fire resisting walls and doors it is a place of “Comparative” Safety until they exit into the open air.

2.2 DETAILS AND DESCRIPTION

Details & description of the Building are contained in the Buildings Fire Risk Assessment.

The escape routes are indicated with the appropriate Safe Condition 'Fire Exit' signage (Green & White Running man) and emergency lighting is provided which will illuminate automatically in the event of an electrical power failure.

The system illuminates all stairways, exit routes and directional signs and changes to floor levels, to enable persons to leave the premises without assistance from normal lighting.

The assembly point available for the building is:

HOWLAND STREET, OUTSIDE MULTI YORK



3.0 Means for Giving Warning in Case of Fire

3.1 INTRODUCTION

In any building, which is used as a workplace there should be a means of giving warning in the event of a fire. Therefore a fire alarm should be provided to give warning to persons in case of fire in the building. This can be a manually operated system, which consists of break glass call points located at entrances onto the main fire exit routes, or in larger buildings automatic detection systems are fitted throughout to detect fire & smoke.

3.2 Details and Description

Fire Alarm System

Network Building has been fitted with a State of the Art fire detection system the fire alarm can be activated, either by breaking the glass cover on one of the red call points or automatically when a smoke/heat detector is triggered. The red call point units are located adjacent to the fire exit doors leading to the stairways and in some of the corridors in addition there are red call points within the tenants demised areas.

The system is fully automatic. On actuation of the alarm it will sound (continuous warbling siren) on all floors, the lifts will go to the ground floor and their doors will open. The plant is automatically shut down.

The Main Fire Panel is Located in the reception area of 78 Whitfield Street to the left of the main entrance. A repeater panel has been located at the reception area of Network Building, directly behind the main reception desk.

When triggered the system is in full alarm which starts the building evacuation process where all occupants are to leave the building

There is also a manual alarm activation button on the Fire Panel itself if needed.

The fire alarm system is powered from the supply authority's mains through a separate main switch-fuse. A secondary source of power is by way of batteries continuously charged by an AC mains operated charger which in the event of a mains failure will continue to operate the system.

The fire alarm is tested on a weekly basis @ **11:05 am** each Tuesday morning to test its operational effectiveness. Should any defects or issues be observed during the test please notify the reception on: **020 7436 0973**.

4.0 Means for Fighting Fire

4.1 Introduction

Under The Regulatory Reform Order 2005 (Fire Safety) (RRO), it is a requirement, where people are employed to work, to provide a means for fighting fire. This includes portable fire fighting equipment.

4.2 Hose Reel Risers & Sprinklers System

Network Building is fitted with 2 hose reels within the carpark of the building. The purpose of a hose reel riser system is to ensure the Fire Brigade have high pressure water available to draw on the supply. The Fire Brigade will be advised of these areas upon arrival.

A sprinkler system is fitted in the carpark that will automatically deploy high pressure water on fire detection to extinguish flames.

4.3 Smoke Ventilation System

When the Fire Alarm System is activated, smoke window vents will open on each floor landing of the staircases. These will draw any smoke out of the staircases area allowing for a safer evacuation.

4.4 Safe Haven / Refuge

Network Building's Safe Haven / Refuge point is on the main staircase lift lobbies protected by fire resisting doors and a smoke ventilation system.

These are on every staircase landing, throughout the building and will protect the occupiers from smoke and flame for up to an hour.

They are intended for use by non-ambulant persons or persons who are unable to evacuate the building via the staircases.

It allows for persons in the Safe Havens / Refuge areas to be evacuated by the Fire Brigade via the reception.

4.5 Fire Resisting Doors

The doors: -

Office doors and ones which open onto the fire escape stairways at all levels that are signed with a blue disk, marked "Fire Door Keep Shut"

To cupboards, plant rooms and service riser ducts in the tenanted and common parts, and which are signed "Fire Door Keep Locked"

These are fire-resisting doors and should either be kept shut or locked. They should not be wedged or held open in any way. If they are, or if they do not close into the door - frame correctly, please report the fact to reception. This requirement is to ensure that, in the event of a fire, the fire escape routes from the upper floors of the building, i.e. the fire escape stairways, are protected from smoke and flame, enabling employees and visitors to safely make their escape, and to prevent fire spreading from floor to floor.

4.6 Portable Fire Fighting Equipment

Portable fire extinguishers are provided in the reception Area and Plant Rooms. Each extinguisher has a label on it that describes its method of operation and the type of fire it can be used to extinguish.

Types of Fire Extinguishers used in the Reception Area and Plant Rooms and either Chrome, CO2 and Foam their uses and colour coding are compliant with BS EN 3: 1999. In the Plant Areas Red CO2 & Foam their uses and colour coding are also compliant with BS EN 3: 1999

The contents of an extinguisher are indicated by a coloured zone on the body of the extinguisher.



<u>Type</u>	<u>Used on the following</u>
Water	Carbon based fires involving paper, wood, cloth, etc.
Foam	Flammable liquids, petrol etc and Carbon based fires involving paper, wood, cloth, etc.
Carbon Dioxide	Electrical, Flammable liquids, petrol etc and other fires where use of water would be dangerous
Powder	Often termed the 'multi-purpose' extinguisher, It can be used on paper, wood, plastic. On Liquids petrol, oil etc. Flammable Gases such as propane, butane, methane)

You should make yourself aware of the location your Fire Extinguishers their method of operation and the type of fire each is suitable to extinguish (See chart above), so that in the event of a fire you do not have to search for one.

Fire Extinguishers within the tenant's demise are the tenant's responsibility and must be serviced annually.

5.0 Discovering a Fire

5.1 All Persons

- If you discover a fire you should follow the steps outlined below.



Fire Action

If you discover a fire



Operate the nearest fire alarm point



Call the Fire Brigade by telephoning 999 and state there is a FIRE at: Network Building, 97 Tottenham Court Road, London, W1T 4TP



Leave the building by the nearest exit



Report to the person in charge on arrival at the assembly point on Howland Street



Do not stop to collect personal Belongings

Fire Evacuation Procedures

Network Building, 97 Tottenham Court Road, London, W1

- 1 Operate the nearest call point.
- 2 Call the Fire Brigade, Dial 999
- 3 Fight the fire, if safe and trained to do so.
- 4 Leave the building by the nearest safe route
- 5 Do not stop to collect belongings
- 6 Do not use the lifts
- 7 Proceed to the assembly area.

The assembly point available for the building is:

HOWLAND STREET, OUTSIDE MULTI YORK



6.0 Evacuation Procedure

On hearing the evacuation fire alarm sound, the following should be carried out:

6.1 All Persons

- Must evacuate the building by the nearest available escape route. If you have visitors or contractors with you, instruct them to follow you.
- Close doors & windows without causing delay.
- **DO NOT STOP TO COLLECT PERSONAL BELONGINGS.**
- Leave the building by calmly walking to the assembly point, never run.
- **DO NOT RE-ENTER THE BUILDING UNTIL INSTRUCTED TO DO SO.**

6.2 Once an evacuation has started the procedure must be completed. This is to prevent accidents by the merging of persons going out and persons going back in.

6.3 *DISABLED PERSONS*

- Disabled Persons must be escorted to the relevant **assembly area** with a 'Buddy'.
- Disabled Persons must not be left alone.

REGARDING EVACUATION OF DISABLED PEOPLE

Be aware of the specific needs of the Disabled Persons and Persons with Impaired Mobility, Vision and Hearing; be aware that each individual will have different needs due to the varying levels of Disability and Impairment.

Wheelchair Users and Persons with Impaired Mobility

Wheelchair Users and Persons with Impaired Mobility should have an identified "Buddy" and they should be moved along the specific escape routes to the identified refuge point (Or a landing on a protected fire stair) Do not attempt to lift the wheelchair or occupant unless you have been specifically trained to do so. All tenants are responsible for their own Disabled Staff, Staff with Impaired Mobility & their Visitors with Disabilities and Impaired Mobility. In addition they must carry out a Personal Emergency Evacuation Plan (PEEP) for each individual (This must be recorded for the Audit Process). Do not use the lifts unless there is a designated Fireman's Lift.

People with Impaired Vision

Look out for the people who may be disoriented. Tell them your name and speak clearly giving them instructions. Use your arm to lead them through the evacuation route identified by the green & white running man. Provide continuous commentary as to where you are going. If you have Employees or Visitors within your demise with Impaired Vision then they also must have a "Buddy". In addition they must carry out a Personal Emergency Evacuation Plan (PEEP) for each individual. Do not point as these gestures will go unnoticed.

People with Impaired Hearing

These people may not have heard the alarm. Attract their attention some way or another and ensure that they follow the evacuation route identified by the running man. All tenants are responsible for their own Staff with Impaired Hearing & their Visitors with Impaired Hearing. In addition they must carry out a Personal Emergency Evacuation Plan (PEEP) for each individual.

Fire Evacuation Procedures

Network Building, 97 Tottenham Court Road, London, W1

6.4 Receptionists

- Ensure a current company visitor evacuation list's is available.

6.5 Reception (Incident Controller)

- On hearing the fire alarm call the Fire Brigade, 'Don' your Hi Visibility Jackets/Vests and take up the following duties.
- The reception, security & concierge / assist with the evacuation and guide people to the Assembly area (**Pedestrian Area on Howland Street**).
- The Building Manager and Building Engineer are to hold access keys, know location of plant areas, riser cupboards, the location of any Hazchem etc and meet the Fire Officer at the reception on his arrival.
- The Receptionist representative will obtain the results of the evacuation from the Tenants Fire Marshals at the assembly point and report them to the Incident Controller. The Incident Controller will obtain results of the evacuation and relay any pertinent information to the Fire Officer.
- Ensure any disabled register is current.
- Prevent unauthorised entry and anyone re-entering the building.

6.6 Fire Warden Duties

On hearing the evacuation fire alarm:-

- The reception will call 999 in consultation with yourself
- Ensure that all persons (including visitors and contractors) in your area of responsibility evacuate by the nearest available escape route immediately.
- Check your area, including toilets, meeting and store rooms to ensure that all personnel under your care have evacuated.
- Do not take personal risks through delay.
- Proceed to the assembly point and await further instructions
- Report to the Reception staff at the assembly point and make your report. e.g. *"Fire Warden of Walker Media 6th floor north. All areas clear", or words to that effect.*

7.0 Assistance to Emergency Services

7.1 Reception

- Ensure all keys are available which could provide access to other areas such as switch rooms, gas shut off valves and plant enclosures.
- Provide precise details as to the location and status of the emergency.
- Provide details of the location and type of any firefighting appliances and risers, if asked.
- Provide the location of fire alarm reset panel, etc.
- Provide details of all specialist and emergency engineers who may be called to provide assistance with plant. In addition ensure that if the Fire Brigade have to get access to any unoccupied floor then they must be given the floor plans, which indicate the route, to take in order to activate the door(s) control Break Glass Units.
- Remember that in an emergency situation, the Senior Fire Officer will assume Absolute Authority until the emergency is over.

8.0 Procedures for Persons Working Out of Normal Hours

This Building is not provided with 24 Hours Security

- 8.1** Out of hours, any person(s) remaining at work must inform the 90 Whitfield Street Building's Reception Staff of their direct dial phone number on **020 7636 3884**. Building reception will therefore know who is still present in the building in the event of a Fire Alarm Activation. All persons must respond to the Fire Alarm Activation by evacuating the building immediately and move directly to the Fire Assembly Point. All persons evacuating must then report to Security Staff at the Assembly Point informing them they have vacated their demised area.
- 8.2** If Security staff at the assembly point does not receive confirmation that occupied areas have been vacated, this must be reported to the fire brigade on arrival.
- 8.3** Once at the assembly point, await further instructions from Security.

9.0 FIRE WATCH CONTINGENCY PLAN –

Fire Evacuation Procedures

Network Building, 97 Tottenham Court Road, London, W1

Network Building Network Building, 97 Tottenham Court Road, London, W1

If for any reason the fire alarm system is taken out of service in your area or suffers a system failure, then a Fire Watch Plan **must be** implemented. This must also be recorded for Audit Purposes

A. Action to be taken on discovering a Fire:-

1. In case of fire the Fire Watch Warden is to raise the alarm by activating the nearest fire alarm system call point and shout **FIRE. FIRE. FIRE.** Notify Reception of the fire.

WORD OF MOUTH, FIRE ALARM or AIR KLAXON HORN MAY RAISE THE ALARM

2. If the fire is considered small enough to be easily and safely extinguished (i.e. a waste paper bin fire) attempt to put the fire out with the nearest correct type of extinguisher, but **Do Not** take personal risks.

ONLY ATTEMPT TO EXTINGUISH A FIRE IF IT IS SAFE TO DO SO AND YOU HAVE A CLEAR ESCAPE ROUTE AWAY FROM THE FIRE. NEVER PUT YOURSELF AT RISK

3. Never attempt to fight large fires.
4. From the floor of the incident the tenant would:
 - Inform Reception / Security –
 - **Telephone: 0207-436-0973 / out of hours Security 0207-636-3884**
5. Inform the other floors in their demise by either or all the following:
 - Activating a Fire alarm call point
 - Shouting **FIRE. FIRE. FIRE.**
 - Sound the Klaxon horns
 - Phone

Security is to immediately inform other tenants Receptions and nominated fire wardens on each floor. **Ring the Fire Brigade**

6. Normal evacuation procedures **must** then come into play.
7. If the fire is considered too large, or if it should get out of control or an escape route is threatened, leave the building quickly and calmly by the nearest available escape route. Wherever possible, assist in the evacuating visitors. **DO NOT** stop to collect personal belongings.
 - Information to be given: Name and address of the premises.
 - Any missing persons
 - Location and type of fire
 - Location and involvement of hazardous materials
9. Report to the Fire Assembly Point. Fire wardens to check that their area of the building has been evacuated and report this to the nominated person(s).

B. Evacuation Procedures

Fire Evacuation Procedures

Network Building, 97 Tottenham Court Road, London, W1

If you hear the fire alarm or other warning, leave the building in a calm and orderly fashion using the nearest safe fire exit and report to the pre-determined assembly points.

IF YOU CAN!

Switch off any machinery.
Close all doors behind you.
Close windows behind you.

DO NOT!

Use the lifts.
Never delay departure by gathering personal belongings